



# Fire Test Certificate

This is to certify that the specimen described below has been examined by BRANZ Ltd on behalf of

ASSA ABLOY Australia  
235 Huntingdale Road  
Oakleigh, VIC 3166  
Australia

**Test standard:** AS 1530.4:2014, BS 476: Part 22: 1987 and SS 332: 2007

**Specimen name:** Pittella hardware on Pyropanel FR and Pandor doorsets

**Specimen description:** Pyropanel FR 38 mm and 48 mm doorsets and Pandor 48 mm doorsets fitted with any of the range of Pittella hardware listed on the following page.

**Orientation:** Fire exposure from either side

**A full description of the test specimen and the test results are given in BRANZ Test Reports and Assessments:**

BRANZ Fire Assessment Report FC12514-01-3

Conditions of laboratory registration by IANZ do not allow assessments by the Registered Laboratory to be covered by IANZ.

**Regulatory authorities are advised to examine test reports before approving any product.**

**The assessed results were as follows:**


See page 2 for the tested/assessed performance for each doorset

**Certificate issued:** 19 May 2023

**Certificate Number:** FC12514-01-C1-3

**Certificate expiry:** 19 May 2033

Page 1 of 2

  
P Chapman  
Senior Fire Testing  
Engineer  
For BRANZ Limited



This Laboratory is accredited by International Accreditation New Zealand (IANZ). The tests reported herein have been performed in accordance with the laboratory's scope of accreditation.

The National Association of Testing Authorities (NATA) and International Accreditation New Zealand (IANZ) are both signatories of the ILAC Mutual Recognition Agreement.

The following statement is required by the test standard "This certificate is provided for general information only and does not comply with the regulatory requirements for evidence of compliance."



# Fire Test Certificate

Hardware Item	Door Leaf	Fire Resistance Time (minutes)
<b>Pittella lever furniture</b> PC2911 6013-S            6820-S TDH & TLDH MNGK12 MNLS12 MNBN10 MNSA10 MNZP10 MNSH10 MNLU10 Maralina 6013 Arnaldo 6820	Pyropanel FR 38 mm or 48 mm	-/120/30
	Pandor 48 mm	-/60/30
<b>Pittella roses and accessories</b> 789.L 789.Y 789.ER 789.TR 789.TR DDA 789.B 355	Pyropanel FR 38 mm or 48 mm	-/120/30
	Pandor 48 mm	-/60/30
<b>Pittella D handle and Push-Pull plates</b> TDP-300 & TLDP-300 TDP-400 & TLDP-400 TJP02-500 & TLJP02-500 3610.300 3610.400 3610.800 one side only 3620.300 3620.400 3620.800 one side only PC2950 6506-200 6506-260 MDPO-300 MDP-300 MDP-400 MNLU27 MNZP27 MNGK27-500	Pyropanel FR 38 mm or 48 mm	-/120/30
	Pandor 48 mm	-/60/30
<b>HP series butt hinges</b> HP100-FP, HP100-LP	Pyropanel FR 48 mm	-/120/30
	Pandor 48 mm	-/60/30
<b>HP series butt hinges</b> HP75-FP, HP75-LP	Pyropanel FR 38 mm	-/120/30
<b>Salto electronic locks</b> AElement AElement Fusion AElement ANSI	Pyropanel FR 38 mm or 48 mm	-/60/30
	Pandor 48 mm	-/60/30